

Facility: All

Best Practice Title: Calculation Spreadsheet for DC Arc Flash Hazard

Point of Contact: Gary Dreifuerst, LLNL, gdreifuerst@gmail.com, 925-980-4141

Kyle D. Carr, LANL, kcarr@lanl.gov, 505-665-6853

Peter McNutt, Peter.mcnutt@nrel.gov, 303-384-6767

Brief Description of Best Practice: Provide a spreadsheet calculator with equations and methods verified by DOE SMEs allowing for determining arc flash hazard Incident Energy and Arc Flash Boundary for the multiple methods directly and indirectly referenced in NFPA 70E.

Why the best practice was used: Approaches for calculating Arc Flash Hazard for DC systems are still in development and methods across the DOE complex vary. EFCOG Electrical Safety Task Group tasked a DC Systems Working Group to review some examples of approaches to determine best practices. A review of the example methods provided allowed the working group to develop and consolidate to a single referenced spreadsheet to submit to the complex as a reviewed set of methods for DC Arc Hazard analysis.

What are the benefits of the best practice: The provided spreadsheet has been reviewed by DC Electrical Safety Subject Matter Experts (SME) to determine that the approaches are valid for use across the DOE complex. The spreadsheet allows for the use of 3 approaches for calculating arc flash with user provided inputs. This allows greatest flexibility for the knowledgeable user to work with the method that best fits the circumstances of the situation.

What problems/issues were associated with the best practice: DC Arc Flash calculations methods were introduced to NFPA 70E in the 2012 edition. Only one method was introduced in the guide but references were made to other more complicated methods. Use of the spreadsheet requires some specialized knowledge of the field of DC arc flash calculation to best choose the option that best describes the situation. Instructions are provided for each sheet and a reference sheet is added to allow the user to determine the method that applies to the situation.

Because of the variety of approaches to estimate Incident Energy and Arc Flash Boundary, a choice of methods is given. 3 types of Incident Energy and 3 type of Arc Flash Boundary calculation are given as radio button choices for the user.

How the success of the Best Practice was measured: The 2014, 2015 and 2016 EFCOG Electrical Safety Working Group has reviewed a number of approaches to

determine the format and use of the attached spreadsheet. A number of SMEs have used this spreadsheet against their own previous calculation and determined that it gives a reliable calculation.

Description of process experience using the Best Practice: The spreadsheet contains 4 individual worksheets for the user.

The first 3 sheets are used for 3 calculation methods from user inputs. Each of the 3 methods allows for a selection of either Open Air, Closed Box (x3) or Closed Box (Wilkins method).

The first sheet allows the user to input System Voltage, System Short Circuit Current, Clearing Time and Working Distance to determine Incident Energy and Arc Flash Boundary using maximum available power as listed in NFPA 70E Informative Annex D.5 and Doan method. This method requires an estimate of maximum clearing time and is extremely conservative. It is also only applicable to linear systems such as constant resistance battery bank models. Gap effects are not considered.

The second sheet Allows for the input of a custom value for arcing voltage and arcing current as well as an optional input for Photovoltaic Cell Temperature compensation on available energy. This allows the computation for non-linear systems such as PV arrays which would otherwise be underestimated for available energy.

The third sheet is an improvement on the first sheet Doan method by allowing the entry of a Gap into the method. This refines the worst case Maximum Power method to a more realistic estimate of arcing current. The method is referenced but not described in NFPA 70E Informational Annex D.5. The reference is the Ammerman, et.al, application of the Stokes and Oppenlander equations for DC arc current commonly referred to as the Ammerman equations.

The last sheet is a list of references for methods.

The user determines the correct sheet as follows:

If the gap for the possible fault is uncertain or varied, or the gap effects are not important to the answer, and the system is modeled as a resistive system, such as for the Battery Compartment of a UPS, the first sheet is applicable.

If the system is modeled as a non-linear system, such as a Photovoltaic Array, then the second sheet is applicable.

If the system is linear and the gap is well established and important to the solution, such as the bus work in a UPS Cabinet, then the third sheet is applicable.